



Product Service

CERTIFICATE

No. Z2 102627 0023 Rev. 03

Holder of Certificate: **DAS SOLAR CO., LTD.**
No. 43, South of Bailing Rd
324000 Quzhou City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062107114-03

Valid until: 2029-03-12

Date, 2024-03-15

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 102627 0023 Rev. 03

Model(s):

DAS-DH156PA-xxx, xxx= 570 to 610 in step of 5;
 DAS-DH144PA-xxx, xxx= 510 to 565 in step of 5;
 DAS-DH132PA-xxx, xxx= 470 to 515 in step of 5;
 DAS-DH120PA-xxx, xxx= 425 to 470 in step of 5;
 DAS-DH108PA-xxx, xxx= 385 to 425 in step of 5;
 DAS-DH156NA-xxx, xxx=585 to 635 in step of 5;
 DAS-DH144NA-xxx, xxx=530 to 590 in step of 5;
 DAS-DH132NA-xxx, xxx=485 to 540 in step of 5;
 DAS-DH120NA-xxx, xxx=445 to 490 in step of 5;
 DAS-DH108NA-xxx, xxx=400 to 440 in step of 5;
 DAS-DH144ND-xxx, xxx=580 to 610 in step of 5;
 DAS-DH108ND-xxx, xxx=435 to 460 in step of 5;
 DAS-DH132NE-xxx, xxx=580 to 615 in step of 5;
 DAS-DH96NE-xxx, xxx=420 to 445 in step of 5;
 DAS-DH108NE-xxx, xxx=475 to 500 in step of 5;
 DAS-DH120ND-xxx, xxx=485 to 505 in step of 5;
 DAS-WH156NA-xxx, xxx=580 to 630 in step of 5;
 DAS-WH144NA-xxx, xxx=535 to 585 in step of 5;
 DAS-WH132NA-xxx, xxx=490 to 535 in step of 5;
 DAS-WH120NA-xxx, xxx=445 to 485 in step of 5;
 DAS-WH108NA-xxx, xxx=400 to 435 in step of 5;
 DAS-WH156PA-xxx, xxx=575 to 610 in step of 5;
 DAS-WH144PA-xxx, xxx=530 to 565 in step of 5;
 DAS-WH132PA-xxx, xxx=485 to 515 in step of 5;
 DAS-WH120PA-xxx, xxx=440 to 470 in step of 5;
 DAS-WH108PA-xxx, xxx=400 to 425 in step of 5;
 xxx is standing for rated output power at STC

Parameters:

| | |
|----------------------|--|
| Safety Class: | ClassII |
| Max. System Voltage: | 1500V DC |
| Test Laboratory: | Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China. |
| Construction: | Framed with Junction box, cable and connector. |
| Fire Safety Class: | Class C according to UL790 |

Tested according to:

IEC 61215-1:2021
 IEC 61215-2:2021
 IEC 61215-1-1:2021
 IEC 61730-1:2023
 IEC 61730-2:2023